


GasMultiBloc Combined regulator and safety shut-off valves Singlestage function

MB-D(LE) 415 - 420 B01





Technical description

The DUNGS GasMultiBloc integrates filter, regulator, valves and pressure switches in one compact fitting. Various designs are possible by the modular system:

- Dirt trap: microfilter
- One regulator and two valves: B01
- Two valves are fast opening
- One valve is fast opening and one valve is slow opening
- Solenoid valves up to 360 mbar as per DIN EN 161 Class A Group 2
- Sensitive setting of output pressure by proportional regulator as per DIN EN 88 Class A Group 2
- High flow rates with low pressure drop
- DC solenoid drive interference degree N
- Main volume restrictor at valve V2
- Hydraulic opening delay
- Flange connections with pipe threads as per ISO 7/1
- Simple mounting, compact, light-weight

The modular system permits individual solutions by using external ignition gas tap in connection with separately controlled valves, by adding a valve proving system, mini/maxi pressure switches, pressure limiters, limit switch at valve V2.

Application

The modular system permits individual solutions in gas safety and regulator engineering. Suitable for gases of families 1, 2, 3 and other neutral gaseous media.

Approvals

EU type test approval as per EU Gas Appliance Directive.

MB-...415-420 B01 CE-0085 AP 3156

EC type test approval as per EC Pressure **Equipment Directive:**

MB-...415-420 B01 CE0036

Approvals in other important gas consuming countries.

Printed in Germany • Rösler Druck • Edition 06.04 • Nr. 225 758

งบริษัท เอดีดี เฟอร์เนส จำกัด PAdd Furnace Co., Ltd. Line ID: @add11 e-mail: add028883472@gmail.com

44 ซ.บรมราชชนนี 70 ถ.บรมราชชนนี ศาลาธรรมสพน์ ทวีวัฒนา กทม. 10170.

website: https://www.add-furnace.com/ โทร: 02-888-3472

Functional description of gas flow

- 1. When the valves V1 and V2 are closed, chamber A is under inlet pressure.
- 2. A hole D in the filter housing connects min. pressure switch with chamber A. If the inlet pressure applied to the pressure switch exceeds the incoming reference value, it switches through to the automatic burner control.
- 3. After release by the automatic burner control, valves V1 and V2 open. The gas flows through chambers A, B and C of the GasMultiBloc.

Operating method of valve-regulator combination on valve V1

A regulator, compensating for residual pressure is integrated in valve V1 (pressure regulating part). Armature 7 is not connected with valve plate unit 3. When it opens, armature 8 pretensions compression spring (V1) 5 and releases the valve plate unit.

When the valve closes, the armature acts directly on the valve plate unit.

The output pressure upstream of valve V2 is defined by pretensioning regulating spring 8 (tension spring) via setting screw 17.

The output pressure acts via opening E on the working diaphragm 21 of the regulator part. In regulated state, setting spring inlet pressure and pressure of working diaphragm are in force equilibrium.

The compensating diaphragm 22 ensures the fast closing fun ction of valve V1 and a high regulating quality.

Operating method of valve V2


The armature 14 of valve V2 is connected to valve plate unit 12. When it opens, armature 14 pretensions the closing spring 13. The max. valve opening can be set by limiting the armature stroke by means of the main volume restrictor 18.

Min. opening (residual stroke) of valve (0.5 to 1.0 mm)


The main volume restrictor 18 is set by rotating the adjusting plate or the hydraulic brake 20. The fast and/or slow opening characteristic is influenced by setting fast stroke 19 at the hydraulic brake under the cover.


Closing function

When the supply voltage to the solenoid coils of valves V1 and V2 is interrupted, they are closed within < 1 s by the compression springs.



- Microfilter
- Valve V1
- Connection flange
- Closing spring V1
- Housing
- Armature V1
- Regulating spring
- 10 Gas pressure switch
- Electrical connection Valve V2 12
- 13 Closing spring V2
- 14 Armature V2
- 15 Solenoid V2 Solenoid housing
- 17 - Gas pressure pa - Main volume
- Fast stroke 19 20 Hydraulic brake
- 21 Working diaphragm
 - Compensation diaphragm









Specifications


•							
Nominal diameters Flange with pipe threads as per ISO 7/1 (DIN 2999)	MB-D 41 Rp 1, 1 1/4 and their co		MB-D 420 Rp 1, 1 1/4, 1 and their com	1/2, 2			
Max. operating pressure	360 mbar (36 kPa)						
Output pressure ranges	MB S20/S22 p _a : 4 mbar to 20 mbar MB S50/S52 p _a : 20 mbar to 50 mbar						
Pressure stage	PN 1			_			
Media	Gases of fa	amilies 1, 2, 3 and other	r neutral gaseous media	3			
Ambient temperature	-15 °C to +70 °C (Do not operate MB-D below 0 °C in liquid gas systems. Only suitable for gaseous liquid gas, liquid hydrocarbons destroy sealing materials.)						
Dirt trap	Sieve with 0.8 mm mesh width, filter made of random laid nonwoven fabric, microfilter, two layer, changing the filter is possible without removing the valve.						
Pressure switches	Types GWA5, ÜBA2 / NBA2 to DIN EN 1854 may be attached. For further information, refer to Datasheets 5.02 and 5.07 "Pressure Switches for DUNGS Multiple Actuators"						
Pressure regulator	Pressure regulator compensated for residual pressure, leakproof seal when switched off be means of valve V1 as per DIN EN 88 Class A. Setpoint spring permanently installed (no spring exchange possible). A vent line above roof is not required. Internal pulse tap provided.						
Solenoid valve V1 Solenoid	Valve as pe	er DIN EN 161 Class A	Group 2, fast closing, fa	ast opening Valve			
valve V2	as per DIN	EN 161 Class A Group	2				
		Valve V2 design		Main volume restrictor			
	MB	fast closing	fast opening	without			
	MB-D	fast closing	fast opening	with			
	MB-DLE	fast closing	slowly opening	with			
	MB-LE	fast closing	slowly opening	without			
Measuring / Ignition gas connection	For G 1/8 as per DIN ISO 228, refer to Pressure taps on page 2						
Burner pressure monitor p _{Br}	Connection downstream of valve V2, pressure switch mountable on adapter laterally 50 - 60						
Voltage / Frequency	Hz 220 - 230 V AC -15 % +10 % Other preferred voltages: 240 VAC, 110 - 120 VAC, 48 VDC, 24 - 28 VDC						
Electrical connection	Plug connection as per DIN EN 175301-803 for valves and pressure switches						
Rating / Power consumption Switch-on duration Degree of protection Radio interference	at 230 V AC; +20 °C: refer to Dimensions on page 5 100% IP 54 as per IEC 529 (EN 60529) Interference degree N						
Materials of gas conveying parts	Housing Diaphragms, seals Solenoid drive		aluminium die casting NBR basis, Silopren (silicone rubber) steel, brass, aluminium				
	Solenoid vertically upright or lying horizontally as well as its intermediate positions.						
Installation position	Solenoid vi	ertically uprignit or lying	monzontally as well as i	to intermediate positions.			

A บริษัท เอดีดี เฟอร์เนส จำกัด 44 ซ.บรมราชชนนี 70 ถ.บรมราชชนนี ศาลาธรรมสพน์ ทวีวัฒนา กทม. 10170. website: https://www.add-furnace.com/ โทร: 02-888-3472 Add Furnace Co.,Ltd. Line ID: @add11 e-mail: add028883472@gmail.com

Equipment variants GasMultiBlocB01 Single-stage function	415 B01	420 B01	
MB	•	•	
MB-D	•	•	
MB-DLE	•	•	
MB-LE	•	•	
Microfilter	•	•	Filter element can be removed. A suitable GF/1
Gas pressure switch			gas filter must then be fitted upstream.
downstream of filter	•	•	
downstream of valve V2 on adapter	•	•	
Pressure regulator	•	•	
Valve V1, double seat	•	•	
Valve V2, double seat	•	•	
Valves opening together	•	•	
Valves opening separately	•	•	
Flange Rp 1	•	•	
Rp 1 1/4	•	•	• = possible
Rp 1 1/2	•	•	(•) = on request
Rp 2	•	•	- = not possible








Туре	Rp	Opening time	\(\text{Nominal rating[VA]} \(\text{-(AC) 230 VAC; +20°C} \) \(\text{S20 S22 S50 S52} \)	Weight [kg]
MB-D 415 B01	Rp 1 - 2	<1s	50 96 50 96	6.5
MB-DLE 415 B01	Rp 1 - 2	< 20 s	50 96 50 96	6.6
MB-D 420 B01	Rp 1 - 2	< 1 s	80 100 80 100	7.7
MB-DLE 420 B01	Rp 1 - 2	< 20 s	80 100 80 100	7.8



GasMultiBloc Combined regulator and safety shutoff valves Single-stage function

MB-D(LE) 415 - 420 B01





We reserve the right to make any changes in the interest of technical progress.